

Message

From: Jeff Stone (ADH) [Jeffery.Stone@arkansas.gov]
Sent: 6/16/2021 2:18:45 PM
To: Mistry, Jatin [Mistry.Jatin@epa.gov]
Subject: FW: Humphrey Site Visit
Attachments: Humphrey 6-10-21.pdf

Jeff Stone, P.E.
Director, Engineering Section
Arkansas Department of Health

From: Jake Chatman <Jake.Chatman@arkansas.gov>
Sent: Tuesday, June 15, 2021 10:37 AM
To: Jeff Stone (ADH) <Jeffery.Stone@arkansas.gov>
Cc: Lance Jones <Lance.Jones@arkansas.gov>; Glenn Greenway <Glenn.Greenway@arkansas.gov>
Subject: Humphrey Site Visit

I met with Humphrey's operator, the mayor of Humphrey, James Dreher from Landmark Engineering, and Calvin Reynolds from Jack Tyler Engineering yesterday at Humphrey's treatment plant. Mr. Reynolds is going to give a quote for filter media matching the original media as soon as possible. He said it would be end of the week at the earliest. Mr. Dreher is going to proceed with planning the replacement and said he is treating it as an emergency situation. Humphrey has a city council meeting this week where they will approve the project according to the mayor and two council members. Please let me know if you have any questions about the site visit yesterday.

I have also attached a memo summarizing the site visit on Thursday of last week. The bacteriological samples were both safe.

Regards,

Jake Chatman, E.I.
District Engineer
ADH Engineering Section
(501) 661-2892